



IMPLANTATION DU MATERIEL

MODELES	COMP.	PUISS.	Ø A	Ø A'	Ø R	Ø R'	Ø L	Ø D	Ø S	Ø AA	Ø LL	Ø RR	DESURCHAUFFEUR
300	CP 1 CP 2	1x15 1x15	1"3/8 1"3/8	2"1/8	7/8" 7/8"	1"1/8	7/8"	1"3/8	1"5/8	2"5/8	1"1/8	1"3/8	EXEL 8-30
250	CP 1 CP 2	1x15 1x10	1"3/8 1"1/8	1"5/8	7/8" 3/4"	1"1/8	7/8"	1"1/8	1"5/8	2"1/8	1"1/8	1"3/8	EXEL 8-30
200	CP 1 CP 2	1x10 1x10	1"1/8 1"1/8	1"5/8	3/4" 3/4"	7/8"	7/8"	1"1/8	1"5/8	2"1/8	1"1/8	1"1/8	EXEL 8-20
150	CP 1	1x15	1"3/8	1"3/8	7/8"	7/8"	5/8"	1"1/8	7/8"	1"5/8	7/8"	1"1/8	EXEL 4-20
100	CP 1	1x10	1"1/8	1"1/8	3/4"	3/4"	5/8"	7/8"	7/8"	1"3/8	7/8"	7/8"	EXEL 4-20

PG	34	28.09.00	RAJOUTER CONTROL TEMPERATURE REFOULEMENT
MODIFIE PAR	IND	N.ETUDE	DATE
		APPAREIL OU UNITE	MATIERE:
		CD 100 A 300	
		DESIGNATION	ECHELLE
		SCHEMA FRIGORIFIQUE	TRAITEMENT
		1 COMP 1 CIRC	MASSE:
		NUMERO DE COMMANDE:	REPLACE PAR:
		NOTE D'ETUDE:	REPLACE:
		VERIFIE PAR:	FORMAT
		DESSIN PAR:	FOLIO
		BARRAL A	NUMERO DE PLAN
		DATE: 18.09.98	INDICE
			A3 3956384 34